



State of New Hampshire  
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095  
(603) 271-3503 FAX (603) 271-5171



November 6, 2003

**LETTER OF DEFICIENCY #WSEB 03-288**  
**CERTIFIED MAIL 7000 0600 0023 9932 7181**

Carol Levine  
BJ'S Wholesale Club, Inc  
One Mercer Road  
Natick, MA 01760

Subject: Tilton – Public Water System: BJ'S Wholesale Club, Inc. (EPA #2356080)

Dear Ms. Levine:

The records of the Department of Environmental Services (DES) show that BJ'S Wholesale Club, Inc. water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Administrative Rule Env-Ws 325.

DES records show that Standard Maximum Contaminant Level (MCL) violations for total coliform bacteria, as defined in NH Admin. Rule Env-Ws 315.01, have occurred and that letters of violation were issued for the following months:

**September 2003 and October 2003**

DES believes the MCL violations can be corrected and future violations prevented by taking the following actions:

- By November 20, 2003**, retain the services of a qualified water system consultant to address the system's water quality problems relative to the recent bacteriological occurrences; and
2. **By December 4, 2003**, submit to DES for review a copy of the consultant's report which shall include recommendations to correct the bacteria contamination; and
3. **By December 18, 2003**, submit to DES for review and approval an implementation schedule which identifies specific dates by which steps to correct the bacteria contamination will be accomplished.

**Letter of Deficiency #WSEB 03-288**

BJS Wholesale Club, Inc.

November 6, 2003

Page 2 of 2

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies be corrected, initiating an administrative fine proceeding and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

**Please be reminded to carry out the public notice requirements and provide proof of public notice to DES for the October sampling violation.**

The copy of the consultant's written report **and the implementation schedule** as requested above should be addressed as follows:

Anne S. Bailey  
Department of Environmental Services  
Water Supply Engineering Bureau  
6 Hazen Drive, P.O. Box 95  
Concord, NH 03302-0095

Please contact Anne Bailey by phone at (603) 271-0672 or by e-mail at [abailey@des.state.nh.us](mailto:abailey@des.state.nh.us) if you have any questions regarding this letter.

Sincerely

 **COPY** for APC

Anthony P. Giunta, P.G., Administrator  
Water Supply Engineering Bureau

h:\wseblenfon\enforce\lods\bacteria\2003\2356080 mcl 03-288.doc

cc: Gretchen Rule, DES Legal Unit  
Town of Tilton Health Officer  
John Benham, Pump Systems, Inc., Primary Operator  
EPA Region I